

Law (1931) Department.
General
MS SERIES. ✓

G.O. No. 4301

DATED 25-11-31

[Despatch Abstract.]

Petroleum - B Licence - 2,000 gallons - Messrs. K. Rama Rao and Ram Mangesh, Agents, the Burma Shell Oil Storage and Distributing Co. of India Ltd. - Udipi - granted.

Law (General)

DEPARTMENT.

Received 19

Registered 19

Subject.

Petroleum - dangerous - storage - 2000 gallons - at house
than in bulk - licence - grant - Recommended.

ENCLOSURES.

No.

Spare copies

Ref.C.1 No. 10442-31.

Station Mangalore, Dated the 13th November 1931.

From (Name) Khan Bahadur J. Hussain, F.R. S. Law
(Designation) Dt. Magistrate of South Kanara

To The Secretary to the Government of Madras,

Law (General) Department,
Madras.

Sir,

b3 intro I forward the application dated 28-11-1931 of
Messrs. Earned Raju and Ram Kishan, Agents, at
at Udipi requesting that they may be granted licence in
Form B to possess 2000 gallons of dangerous petroleum other-
wise than in bulk in the shed in S.No. 120/34 of the village
village, Udipi Taluk, Udipi Taluk of this District.

2. The building was inspected by the
Assistant Magistrate at Udipi whose report (enclosed), shows
that it is situated in the conditions of the Licence.

b4 intro The applicants have paid the licence fee of Rs. 10 and shall
receipt No. 10 of the 28-11-1931 of the District Magistrate, which

3


To,
The District Magistrate of South Kanara,
MANGALORE.

2288
207

From,
Karnad RamaRao & Ram Mangesh,
Agents, Burnah-Shell,

U D I P I.

Application for license of storage
of Dangerous Petroleum (Other than
bulk) FORM B. for 2000 gallons.



We beg to ~~bring~~ ^{submit} with Udipi Sub-Treasury receipt No. 19/2
for Rs14/- being the license fee for the storage of 2000 gallons
of Petrol in the third room of the shed in the middle of S.No.
120/34. of Mudanidambur Village, Udipi Town, the building be-
longing to Mr. U. Govindraya Venkatraya Poi of Udipi.

The above applied for room had been licensed last year for
the storage of petrol. But this year the former license holder
having not renewed the same for this year for this room, we have
now applied.

So, we beg to request you to kindly arrange for despatch of
the applied for license as early as possible and oblige.

We also beg to bring to your kind notice that the adjoining
two rooms have been already licensed, one to us and the other
to the B.O.C agents.

The rough sketch of the situation of the shed is herewith
attached.

We beg to remain, Sir,

Yours most Obediently.
For RamaRao & Ram Mangesh,

R. K. Karnadkar
Partner.

Udipi.
Dated 28th October 1931.....

8, - 18637-31

N. R. P. - ~~2288/31~~ 10442-31

70
3-11-31 Forwarded to the Tahildar of
Udipi for immediate report whether
the building in question satisfies all
the conditions of the license sought for


30/10/31 & K. K. K. K.

on
In d. J.
24/11/31

Board High School

2nd class Travellers
Bangalore

Mudanidambur Village
Udupi.



Market

Santhekatte Road

C.P.C. office

H.T.C. office

S.V.M. office

Shed ^{Applied for}
S.No. 120/34

Mosque Road

Phalmarmitt Road

Road leading to Temple Square.

Hospital Road

Hospital Compound

N^o 18637 - 2. 6

Resubmitted

The license is applied for the
Southernmost room in the build-
ing specially built in S. No.
 $\frac{120}{34}$ of Meadowlands village.
The other two rooms have been
licensed to store petroleum. The
room has been built of masonry
and plastered with cement.
Its floor has been sunk two and
a half feet below the surface and
the door frame has been placed
 $1\frac{1}{2}$ ft. higher than the surface so
that the pit is 4 ft. deep from the
door frame. The door is of wood
but the shutter is of iron sheet.
There is a small window which
has been covered by iron gauge.
The building has a roof of corrug-
ated iron sheet. It is about
66 ft. distant from the road.
There are no other buildings within
30 ft. from this room.

24 dipi }
10-11-93 1/2 }

Thiange
Sahel Das

Petroleum

B. Licena - 2000 gallons - Measrs.

K. Rama Rao and Ram Mangesh, Agents
The Burmah Shell Oil Storage and Distributing
Company of India Ltd - Ndipic -
Granted.

192

Ref. C-1

C. No. 7783C From the NTY South Kanara, No. 10642-31, dated 13-11-1981.

" " " " " "

192

192

No. 6301, dated 25 - 11 - 1931.

Ms.

P. 1. 5.

Dpd. by Post 10/10/19
 Date 19

A licence in Form B of the Petroleum Rules will be issued to Messrs. Karnad Rama Rao and Ram Mangesh, Agents to Burma Shell Oil Storage and Distributing Company of India at Udipi, for the storage of 2000 (two thousand) gallons of dangerous petroleum in their storage shed at Mudamidambur village, Udipi Taluk, South Kanara Dist. The licence will be forwarded to the S.M. South Kanara for delivery to the applicants.

70

JK D.T. South Kanara (with license
as p. 4 of original)
The Chief Inspector of Ex/ercises
in India (with copy of license)
by the Burmah Shell Company

$$\begin{array}{r} 128 \text{ } 520 \\ \hline 20 \times 131 \quad 2511 \end{array}$$

$\frac{a}{24/11}$
 $\frac{b}{24/11}$

H.E. Rule 1 Ch. IV. Part II

Form B.

(Rule 3 of Chapter IV of Part II.)

**License to possess dangerous petroleum,
otherwise than in bulk, in quantity exceeding
forty gallons.**

No.

Fee, Rs. 14/- / Fourteen

License is hereby granted to Messrs. Karnad Rama Rao and Ram Mangar
Agents, the Burma Shell Oil Storage and Distribution Company of India Ltd.,
for the storage, in the storage shed described below, of 2 000 (two thousand)
gallons of dangerous petroleum, subject to the rules for the
storage of petroleum published in Notification No. 441, dated
24th July 1909 and to the further conditions on the back of this
license.

o/c

Fort St. George

Secretary to the Government of Madras.

Wd
24/11/

Law Department

The November 1931.

(Description of the storage shed above referred to.)

The storage shed is situated in S. No 120/34 of
of Mudanidambur village, Udipi Town, Udipi
Taluk, South Kanara Dt.

128
20 x 121 20/11

25/11

Wd
24/11/

Endorsement on Form B.

CONDITIONS OF LICENSE.

1. If the licensing officer call upon the holder of a license, by notice in writing, to execute any repairs of the storage shed, which may, in the opinion of such officer, be necessary for the safety of the shed, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice, as may be fixed by the notice.

2. The license-holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 or section 6 of the Act, or any less quantity of such petroleum, except in accordance with the conditions of the proviso to section 6 of the Act, as to the vessels in which the petroleum must be contained.

3. The petroleum shall be stored in gas-tight tinned or galvanized sheet iron, steel, or lead plate receptacles containing each not more than forty gallons and fitted with well-made filling holes and well-fitting screw plugs, or fitted with screw cap or other cap with metal air-tight undercap. Such receptacles shall be packed in strong wooden cases, the thickness of the wood to be not less than three-eighths of an inch; provided that wood cases shall not be necessary when the receptacles are made of tinned or galvanized sheet iron or steel, and have the following thickness of metal:—

	Not less than
(1) When the capacity does not exceed two gallons ...	27 B.W.G.
(2) When the capacity exceeds two gallons but does not exceed four gallons ...	22 B.W.G.
(8) When the capacity exceeds four gallons but does not exceed eight gallons ...	20 B.W.G.
(4) When the capacity exceeds eight gallons but does not exceed twenty gallons ...	16 B.W.G.
(5) When the capacity exceeds twenty but does not exceed thirty gallons ...	14 B.W.G.
(6) When the capacity exceeds thirty but does not exceed forty gallons ...	12 B.W.G.
(7) When the capacity exceeds forty but does not exceed sixty-five gallons ...	10 B.W.G.

4. An air-space of at least one-tenth of its capacity shall be left in each receptacle at the time of filling. *thirtieth*

5. The receptacle shall be so substantially constructed and secured as not to be liable except, under circumstances of grave negligence or extraordinary accident, to be broken or become defective, leaky or insecure.

6. The receptacles shall be labelled in accordance with the provisions of section 7 of the Act.

7. Any receptacle, before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same.

8. The storage shed shall be constructed of masonry or other unflammable material with terraced, tiled or iron roofs and with tiled or paved or earthen floors.

9. Either the doorways and other openings of the storage shed shall be built up to a height of two feet above the level of the road or street, or the floor sunk to a depth of two feet below the level of the road or street, so that the petroleum cannot flow out from the building in case of its escape from the receptacle in which it is contained, or the building itself shall be surrounded with a masonry wall or embankment or both not less than two feet high. When the quantity of petroleum stored exceeds 16,000 gallons the height or depth shall be three feet.

A combination of these methods is permissible.

10. All ventilating openings in the storage shed shall be protected by strong wire gauze.

11. No light, except a light of such strength, position and character as is not liable to ignite any inflammable vapour, nor fire of any description, shall be permitted at any time within the storage shed.

12. All due precautions shall be taken for the prevention of unauthorised persons having access to any dangerous petroleum kept and to the vessels containing or having actually contained the same.

13. Every person managing or employed on or in connection with the storage shed shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act.

14. The drum or other receptacle containing dangerous petroleum shall only be opened on the licensed premises at or immediately adjoining the storage shed and for the time necessary for drawing off the petroleum, and during such drawing off every reasonable precaution shall be adopted for preventing the escape of dangerous petroleum or the vapour therefrom.

15. The following distances shall be kept clear from protected works round the storage shed :—

Quantity to be stored	Distances to be kept clear				
Not exceeding 500 gallons	...	...	...	...	20 feet.
From 500 to 1,000 "	...	...	...	...	25 "
" 1,000 to 5,000 "	...	...	...	...	30 "
" 5,000 to 15,000 "	...	...	...	...	40 "
" 15,000 to 25,000 "	...	...	...	...	50 "
" 25,000 to 35,000 "	...	...	...	...	60 "
" 35,000 to 50,000 "	...	...	...	...	70 "
" 50,000 and over "	...	...	...	...	100 "

Provided that these distances may be reduced by the Local Government on the recommendation of the Chief Inspector of Explosives in cases where screen walls are provided or other special precautions taken, or where there are special circumstances that in the opinion of the Chief Inspector of Explosives warrant the reduction.

16. Provided that when the quantity to be possessed does not exceed 60 gallons the provisions of conditions 8, 9 and 15 shall not apply, but the licensee shall observe the following conditions :—

- (i) The storage shed in which the dangerous petroleum is stored shall be well ventilated and constructed of unflammable material, provided however that the doors and windows may be of wood.
- (ii) Where a storage shed forms part of or is attached to another building and when the intervening floor or partition is of an unsubstantial or inflammable character or has openings therein, the whole of such building shall be deemed to be the storage shed and no portion of such storage shed shall be used as a dwelling house or as a place where persons assemble. The storage shed shall have a separate entrance from the open air distinct from any building or dwelling in which persons assemble.

17. The storage shed shall be liable to inspection by an officer not being on lower rank than a Sub-Inspector of Police authorised by the Governor in Council in this behalf.